


PUBLIC NOTICE

On August 7, 2022, sewer lift station located near 207 Alabama Dr. discharged sewer into the nearby storm water drain. The sewer discharge was caused by an alarm failure at the lift station. Amount of sewer discharge was less than 500 gallons. Water samples have been taken and lime applied to the affected area.

Please contact Glenn Davis or Garrett Garland at (850) 247-3001 for questions.



**Glenn Davis
Utilities Director**