

CITY OF MEXICO BEACH
ADA DUNE WALKOVER AT SUNSET PARK



**ADDENDUM NO. 1
REQUESTS FOR INFORMATION**

Issued 01/07/26

The Bid Due Date and Time remains the same. Bids are due on Friday, January 16th, 2026 until 2:00 p.m. (Central).

The following questions were received from potential bidders and are being addressed below:

1. My question is in regard to the 6x6 posts. The most effective way to install them is to jet them down with water. Is this permitted? In years past, we have pulled water from the gulf to jet piles for retaining walls.

City's Response to Request for Information Question No. 1: Jetting is acceptable for 75%, but the final 25% will need to be driven. Note: the Contractor is responsible for obtaining all required permitting approvals from FDEP or any other regulatory agency to accomplish this.

2. Will metal handrails (i.e. grab rails) be required if so will aluminum be approved?

City's Response to Request for Information Question No. 2: The handrails are to be stainless steel.

3. Bolt requirements: Hot Dipped Galvanized HDG or Stainless Steel (SS)? If SS is required what series 304 or 316?

City's Response to Request for Information Question No. 3: Stainless Steel Series 316 is required for bolts.